



PROJECT: BRHS Language Arts & Vocational Center Glycol Addition REBID

GENERAL: Addenda form part of the Contract Documents and modify the original Bid Documents. Addenda are issued prior to bid opening. Acknowledgment of receipt of addenda is required on the bid form. Failure to acknowledge addenda may subject the bidder to disqualification. Form of addenda is outlined below.

Revised ADDENDUM NUMBER: 01

DATE: May 25, 2021

ISSUED BY: DWA Construction, Inc.
Construction Manager, Box Elder School District

TO: All Bidders

This addendum number 01 forms part of the Contract Documents and modifies the original Bid Documents dated December 29, 2016. Acknowledge receipt of this addendum number 01 in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This addendum consists of 02 pages, 01 exhibits, and 0 drawings.

1 – CHANGES TO PRIOR ADDENDUM:

Item 1 – 1: This addendum 01 replaces the original addendum 01, dated April 17, 2020.

2 – CHANGES TO BIDDING REQUIREMENTS:

Item 2 – 1: NA

3 – CHANGES TO AGREEMENT AND OTHER CONTRACT FORMS:

Item 3 – 1: NA

4 – CHANGES TO CONDITIONS OF THE CONTRACT:

Item 4 – 1: NA



5 – CHANGES TO SPECIFICATIONS:

Item 5 – 1: Prior Approvals – See attached Mechanical Addendum dated 4/16/2020.

6 – CHANGES TO DRAWINGS:

Item 6 – 1: See attached Mechanical Addendum dated 4/16/2020.

Item 6-2: Seismic bracing and vibration isolation has been included in the spec. and will be required as part of the project for piping, pumps, heat exchanger, and the new expansion tank. Refer to section 15050 2.3 and 3.4 on drawing M0.1 and Detail 1 on M4.0.

7 – PRE-BID APPROVALS:

Item 7 – 1:

8 – CLARIFICATIONS:

Item 8 – 1: Window of construction:

Work in classrooms and public areas shall be completed before August 20, 2021.

Work in boiler room shall be completed before October 15, 2021.

END OF ADDENDUM