

McKinley Elementary School Boiler Replacement Project

Mechanical Addenda Items

Mortensen Engineering, Inc.

May 21, 2020

Incorporate the following clarifications, revisions, and additions in the contract documents of the above mentioned project. These items become part of the contract documents and the cost of all items shall be included in the contractor's proposal.

Prior Approvals:

The following products and manufacturers are approved in name only and shall meet all the requirements of the contract documents.

| <u>Product</u> | <u>Manufacturer</u> | |
|--------------------------|---------------------|----------|
| Heating Coils | Rae Coil | Approved |
| Expansion Tank | Grundfos | Approved |
| Pumps | Grundfos | Approved |
| VFDs | Grundfos | Approved |
| Triple Duty Valves | Grundfos | Approved |
| Air Separator | Grundfos | Approved |
| Butterfly & Check Valves | ISLIP Flow Controls | Approved |
| Y-Strainers | ISLIP Flow Controls | Approved |
| Flexible Connectors | Twin City Hose | Approved |
| Thermometers & Gauges | Winters Instruments | Approved |
| Balancing Valves | Danfoss | Approved |
| Venturi Valves | Gerand | Approved |

Drawings:

1. Add unit heater UH-1, gas piping, gas pressure regulator, gas vent piping, combustion/flue piping as shown on sheets M1.1 and M2.2.