



## QUESTIONS SUBMITTED BY HVAC CONTRACTORS

Logan City School District  
HVAC Upgrades  
November 15, 2021

1. Do all the accessories on the chillers need to be replaced? I.E. strainers, valves, etc.  
**Any and all accessories required to meet manufacturer warranty will need to be part of bid.**
2. Do you want welded or Victaulic fittings?  
**Welded piping to chillers for base bid. May have bid alternate for grooved fittings.**
3. Can we use a competitive alternate to the Trane chiller? Which manufacturer should be used for the chillers? **Carrier and York are acceptable.**
4. Will the plumbing contractor provide and install the chillers?  
**?**
5. To what extent should the subs plan on providing new piping, valves, regulators, fittings? **To the extent that unit is operational and meets manufacturer warranty after install.**
6. Do we need to install test ports and dirt legs on the piping to bring them up to code?  
**Test port and dirt leg will only be required if/when a new regulator is installed.**
7. May we add Lennox as an approved manufacturer?  
**Yes**