

Quin Whitaker

From: Jeffrey Seedall, PE <jeff.seedall@crsengineers.com>
Sent: Tuesday, June 13, 2023 11:19 PM
To: Quin Whitaker
Cc: Max Pierce, PE
Subject: USU Aggie Village parking lot Rev 1
Attachments: 23.06.12 Aggie Village Rev 1_Reduced.pdf

Quin,

Thank you for forwarding DWA's questions for the bid. We have prepared a revised set of plans to address questions; here are verbal summaries of the changes:

1. The listed quantities for demolition and new construction do not match what I am coming up with when I do the takeoff. Please advise if we should bid the listed quantities or if we should bid what we come up with while doing takeoff.
 - a. *Quantities have been removed from the engineer's plan set. Contractor's are responsible for the quantities in their respective takeoffs.*
2. Will the new trash enclosure be for a single dumpster or double dumpster? Also, there isn't any detail for the footings and foundations for the trash enclosure. Will you please provide a basis of design for this?
 - a. *The new trash enclosure is for a single dumpster; structural details have been added to sheet CD501.*
3. There are 3 different details for the new light poles. Which detail should be used for the new light poles?
 - a. *The light poles for the parking lot are referenced in detail B/ES501 with modifiers in the fixture schedule.*

Thank you,

Jeff Seedall, PE | Engineering Services
CRS ENGINEERING & SURVEYING | 45 E 200 North, Ste 107 | Logan, UT 84321
Main: (435) 374-4670
www.crsengineers.com

Please consider the environment before printing this e-mail. The information in and/or attached to this electronic communication may be privileged, confidential, or proprietary. Use or dissemination of this information by others than the intended recipient(s) is prohibited.