



## DFCM SOLICITATION ADDENDUM COVER PAGE

### DFCM Addendum No.2

**Date:** August 7, 2023  
**To:** Bidding Contractors  
**From:** Carl Francis-DFCM Project Manager  
**Reference:** Main Campus Meat Lab Freezer Floor Repairs  
 DFCM Project 23462210

|                                     | <u>Pages</u> |
|-------------------------------------|--------------|
| <b>Content:</b> Addendum Cover Page | 1            |
| <b>Total Pages:</b>                 |              |
|                                     | 1            |

*Note:* This Addendum shall be included as part of the Contract Documents. Items in this Addendum apply to all drawings and specification sections whether referenced or not involving the portion of the work added, deleted, modified, or otherwise addressed in the Addendum. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to Disqualification.

**2.1 Schedule Changes:** There are no project schedule changes within this Addendum No .2.

**2.2 General Items:** Q&A to U3P submittal:

**Q:** Welded wire mesh is very difficult to get right now. Would it be possible to use #3 bar instead? If so, what spacing would be required on the #3 bar?

**A:** In lieu of Welded Wire Fabric, #3 reinforcement bar at 12” on center each way is an appropriate substitution with the same coverage as suggested in the drawings.