



**820 North 2000 West
Tremonton, Utah 84337**

Phone: (435) 257-3016

Fax: (435) 257-2353

RFI 01

Date: 12-18-2023

To: DWA Construction

Project: Alice Harris Chiller Project

The drawings on the Alice Harris chiller indicate that the 2 VFD's for the pumps in the equipment room are supplied by the electrical contractor. We need to know the required VFD package for this installation so it can connect into the mechanical control system.

*Thanks,
Dar*

The VFD's for pumps P-3 and P-4 are call out to be by the mechanical contractor on the Pump Schedule, note 2.

**Jed Jenkins
VBFA
12/20/2023**