



**820 North 2000 West
Tremonton, Utah 84337**

Phone: (435) 257-3016

Fax: (435) 257-2353

RFI 02

Date: 12-18-2023

To: DWA Construction

Project: Alice Harris Chiller Project

*The drawings on the Alice Harris AHU's have no indication as to how these pumps are turned on or off. The drawings indicate that we are to install disconnects directly from the breaker power but have no starters to turn them on or off. Unless they run all the time starters or contactors will need to be installed. Please advise.
dar*

The pumps require starters to allow for the pumps to be controlled by the building automation system.

Jed Jenkins
VBFA
12/20/2023