

ADDENDUM #02 BID

date: 11/01/2024
project: Montpelier Tabernacle Misc. Work
by: Design West Architects
subject: Bid Addendum #02

This Addendum shall be considered part of the bid documents for the above-mentioned project as though it had been issued at the same time and shall be incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original bid documents. This Addendum shall govern and take precedence. ***Bidders must acknowledge this addendum on their bids.***

Proposers are hereby notified that they shall make any necessary adjustments in their estimates as a result of this Addendum. It will be construed that each bidder's proposal is submitted with full knowledge of all modifications and supplemental data specified herein.

Except as described below, the original bid documents remain unchanged. The bid documents are modified and/or clarified, As follows:

Items:

1. CHANGES TO PRIOR ADDENDA:

- N/A

2. CHANGES TO BIDDING REQUIREMENTS:

- N/A

3. CHANGES TO DRAWINGS & SPECIFICATIONS

- N/A

4. CLARIFICATIONS

ARCHITECTURAL:

- ALL NEW Asphalt Paving is to receive a new base (8" road base course and 24" structural fill course) per detail A3/A-501. This applies to the asphalt in the Northwest corner of the main parking lot and the asphalt in the area of the demolished shed.
- We will only seal coat the NEW asphalt added during this project. We will NOT seal coat the existing asphalt.

5. REVISED SHEETS

- N/A

-- END --