

# Logan City SD Mount Logan Middle School Vestibule Remodel

## SECTION 087100 - DOOR HARDWARE

### PART 1 - GENERAL

#### 1.01 SUMMARY

##### A. Section includes:

1. Mechanical and electrified door hardware
2. Electronic access control system components

##### B. Section excludes:

1. Windows
2. Cabinets (casework), including locks in cabinets
3. Signage
4. Toilet accessories
5. Overhead doors

##### C. Related Sections:

1. Division 01 "General Requirements" sections for Allowances, Alternates, Owner Furnished Contractor Installed, Project Management and Coordination.
2. Division 06 Section "Rough Carpentry"
3. Division 06 Section "Finish Carpentry"
4. Division 07 Section "Joint Sealants" for sealant requirements applicable to threshold installation specified in this section.
5. Division 08 Sections:
  - a. "Metal Doors and Frames"
  - b. "Flush Wood Doors"
  - c. "Interior Aluminum Doors and Frames"
  - d. "Aluminum-Framed Entrances and Storefronts"
6. Division 26 "Electrical" sections for connections to electrical power system and for low-voltage wiring.
7. Division 28 "Electronic Safety and Security" sections for coordination with other components of electronic access control system and fire alarm system.

#### 1.02 REFERENCES

##### A. UL LLC

1. UL 10B - Fire Test of Door Assemblies
2. UL 10C - Positive Pressure Test of Fire Door Assemblies
3. UL 1784 - Air Leakage Tests of Door Assemblies
4. UL 305 - Panic Hardware

##### B. DHI - Door and Hardware Institute

1. Sequence and Format for the Hardware Schedule
2. Recommended Locations for Builders Hardware
3. Keying Systems and Nomenclature
4. Installation Guide for Doors and Hardware

C. NFPA – National Fire Protection Association

1. NFPA 70 – National Electric Code
2. NFPA 80 – Standard for Fire Doors and Other Opening Protectives
3. NFPA 101 – Life Safety Code
4. NFPA 105 – Smoke and Draft Control Door Assemblies
5. NFPA 252 – Fire Tests of Door Assemblies

D. ANSI - American National Standards Institute

1. ANSI A117.1 – 2017 Edition – Accessible and Usable Buildings and Facilities
2. ANSI/BHMA A156.1 - A156.29, and ANSI/BHMA A156.31 - Standards for Hardware and Specialties
3. ANSI/BHMA A156.28 - Recommended Practices for Keying Systems
4. ANSI/WDMA I.S. 1A - Interior Architectural Wood Flush Doors
5. ANSI/SDI A250.8 - Standard Steel Doors and Frames

1.03 SUBMITTALS

A. General:

1. Submit in accordance with Conditions of Contract and Division 01 Submittal Procedures.
2. Prior to forwarding submittal:
  - a. Review drawings and Sections from related trades to verify compatibility with specified hardware.
  - b. Highlight, encircle, or otherwise specifically identify on submittals: deviations from Contract Documents, issues of incompatibility or other issues which may detrimentally affect the Work.

B. Action Submittals:

1. Product Data: Submit technical product data for each item of door hardware, installation instructions, maintenance of operating parts and finish, and other information necessary to show compliance with requirements.
2. Riser and Wiring Diagrams: After final approval of hardware schedule, submit details of electrified door hardware, indicating:
  - a. Wiring Diagrams: For power, signal, and control wiring and including:
    - 1) Details of interface of electrified door hardware and building safety and security systems.
    - 2) Schematic diagram of systems that interface with electrified door hardware.
    - 3) Point-to-point wiring.
    - 4) Risers.
3. Samples for Verification: If requested by Architect, submit production sample of requested door hardware unit in finish indicated and tagged with full description for coordination with schedule.
  - a. Samples will be returned to supplier. Units that are acceptable to Architect may, after final check of operations, be incorporated into Work, within limitations of key coordination requirements.
4. Door Hardware Schedule:
  - a. Submit concurrent with submissions of Product Data, Samples, and Shop Drawings. Coordinate submission of door hardware schedule with scheduling requirements of other work to facilitate fabrication of other work critical in Project construction schedule.

Logan City SD Mount Logan Middle School Vestibule Remodel

- b. Submit under direct supervision of a Door Hardware Institute (DHI) certified Architectural Hardware Consultant (AHC) or Door Hardware Consultant (DHC) with hardware sets in vertical format as illustrated by Sequence of Format for the Hardware Schedule published by DHI.
  - c. Indicate complete designations of each item required for each opening, include:
    - 1) Door Index: door number, heading number, and Architect's hardware set number.
    - 2) Quantity, type, style, function, size, and finish of each hardware item.
    - 3) Name and manufacturer of each item.
    - 4) Fastenings and other pertinent information.
    - 5) Location of each hardware set cross-referenced to indications on Drawings.
    - 6) Explanation of all abbreviations, symbols, and codes contained in schedule.
    - 7) Mounting locations for hardware.
    - 8) Door and frame sizes and materials.
    - 9) Degree of door swing and handing.
    - 10) Operational Description of openings with electrified hardware covering egress, ingress (access), and fire/smoke alarm connections.
5. Key Schedule:
- a. After Keying Conference, provide keying schedule that includes levels of keying, explanations of key system's function, key symbols used, and door numbers controlled.
  - b. Use ANSI/BHMA A156.28 "Recommended Practices for Keying Systems" as guideline for nomenclature, definitions, and approach for selecting optimal keying system.
  - c. Provide 3 copies of keying schedule for review prepared and detailed in accordance with referenced DHI publication. Include schematic keying diagram and index each key to unique door designations.
  - d. Index keying schedule by door number, keyset, hardware heading number, cross keying instructions, and special key stamping instructions.
  - e. Provide one complete bitting list of key cuts and one key system schematic illustrating system usage and expansion. Forward bitting list, key cuts and key system schematic directly to Owner, by means as directed by Owner.
  - f. Prepare key schedule by or under supervision of supplier, detailing Owner's final keying instructions for locks.
- C. Informational Submittals:
- 1. Provide Qualification Data for Supplier, Installer and Architectural Hardware Consultant.
  - 2. Provide Product Data:
    - a. Certify that door hardware approved for use on types and sizes of labeled fire-rated doors complies with listed fire-rated door assemblies.
    - b. Include warranties for specified door hardware.
- D. Closeout Submittals:
- 1. Operations and Maintenance Data: Provide in accordance with Division 01 and include:
    - a. Complete information on care, maintenance, and adjustment; data on repair and replacement parts, and information on preservation of finishes.
    - b. Catalog pages for each product.
    - c. Final approved hardware schedule edited to reflect conditions as installed.
    - d. Final keying schedule
    - e. Copy of warranties including appropriate reference numbers for manufacturers to identify project.
    - f. As-installed wiring diagrams for each opening connected to power, both low voltage and 110 volts.

## Logan City SD Mount Logan Middle School Vestibule Remodel

### E. Inspection and Testing:

1. Submit written reports to the Owner and Authority Having Jurisdiction (AHJ) of the results of functional testing and inspection for:
  - a. Fire door assemblies, in compliance with NFPA 80.
  - b. Required egress door assemblies, in compliance with NFPA 101.

## 1.04 QUALITY ASSURANCE

### A. Qualifications and Responsibilities:

1. Supplier: Recognized architectural hardware supplier with a minimum of 5 years documented experience supplying both mechanical and electromechanical door hardware similar in quantity, type, and quality to that indicated for this Project. Supplier to be recognized as a factory direct distributor by the manufacturer of the primary materials with a warehousing facility in the Project's vicinity. Supplier to have on staff, a certified Architectural Hardware Consultant (AHC) or Door Hardware Consultant (DHC) available to Owner, Architect, and Contractor, at reasonable times during the Work for consultation.
2. Installer: Qualified tradesperson skilled in the application of commercial grade hardware with experience installing door hardware similar in quantity, type, and quality as indicated for this Project.
3. Architectural Hardware Consultant: Person who is experienced in providing consulting services for door hardware installations that are comparable in material, design, and extent to that indicated for this Project and meets these requirements:
  - a. For door hardware: DHI certified AHC or DHC.
  - b. Can provide installation and technical data to Architect and other related subcontractors.
  - c. Can inspect and verify components are in working order upon completion of installation.
  - d. Capable of producing wiring diagram and coordinating installation of electrified hardware with Architect and electrical engineers.
4. Single Source Responsibility: Obtain each type of door hardware from single manufacturer.

### B. Certifications:

1. Fire-Rated Door Openings:
  - a. Provide door hardware for fire-rated openings that complies with NFPA 80 and requirements of authorities having jurisdiction.
  - b. Provide only items of door hardware that are listed products tested by UL LLC, Intertek Testing Services, or other testing and inspecting organizations acceptable to authorities having jurisdiction for use on types and sizes of doors indicated, based on testing at positive pressure and according to NFPA 252 or UL 10C and in compliance with requirements of fire-rated door and door frame labels.
2. Smoke and Draft Control Door Assemblies:
  - a. Provide door hardware that meets requirements of assemblies tested according to UL 1784 and installed in compliance with NFPA 105
  - b. Comply with the maximum air leakage of 0.3 cfm/sq. ft. (3 cu. m per minute/sq. m) at tested pressure differential of 0.3-inch wg (75 Pa) of water.
3. Electrified Door Hardware
  - a. Listed and labeled as defined in NFPA 70, Article 100, by testing agency acceptable to authorities having jurisdiction.

4. Accessibility Requirements:
  - a. Comply with governing accessibility regulations cited in "REFERENCES" article 087100, 1.02.D3 herein for door hardware on doors in an accessible route. This project must comply with all Federal Americans with Disability Act regulations and all Local Accessibility Regulations.

C. Pre-Installation Meetings

1. Keying Conference
  - a. Incorporate keying conference decisions into final keying schedule after reviewing door hardware keying system including:
    - 1) Function of building, flow of traffic, purpose of each area, degree of security required, and plans for future expansion.
    - 2) Preliminary key system schematic diagram.
    - 3) Requirements for key control system.
    - 4) Requirements for access control.
    - 5) Address for delivery of keys.
2. Pre-installation Conference
  - a. Review and finalize construction schedule and verify availability of materials, Installer's personnel, equipment, and facilities needed to make progress and avoid delays.
  - b. Inspect and discuss preparatory work performed by other trades.
  - c. Inspect and discuss electrical roughing-in for electrified door hardware.
  - d. Review sequence of operation for each type of electrified door hardware.
  - e. Review required testing, inspecting, and certifying procedures.
  - f. Review questions or concerns related to proper installation and adjustment of door hardware.
3. Electrified Hardware Coordination Conference:
  - a. Prior to ordering electrified hardware, schedule and hold meeting to coordinate door hardware with security, electrical, doors and frames, and other related suppliers.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Inventory door hardware on receipt and provide secure lock-up for hardware delivered to Project site. Promptly replace products damaged during shipping
- B. Tag each item or package separately with identification coordinated with final door hardware schedule, and include installation instructions, templates, and necessary fasteners with each item or package. Deliver each article of hardware in manufacturer's original packaging.
- C. Maintain manufacturer-recommended environmental conditions throughout storage and installation periods.
- D. Provide secure lock-up for door hardware delivered to Project. Control handling and installation of hardware items so that completion of Work will not be delayed by hardware losses both before and after installation.
- E. Handle hardware in manner to avoid damage, marring, or scratching. Correct, replace or repair products damaged during Work. Protect products against malfunction due to paint, solvent, cleanser, or any chemical agent.
- F. Deliver keys to manufacturer of key control system for subsequent delivery to Owner.

## Logan City SD Mount Logan Middle School Vestibule Remodel

### 1.06 COORDINATION

- A. Coordinate layout and installation of floor-recessed door hardware with floor construction. Cast anchoring inserts into concrete.
- B. Installation Templates: Distribute for doors, frames, and other work specified to be factory or shop prepared. Check Shop Drawings of other work to confirm that adequate provisions are made for locating and installing door hardware to comply with indicated requirements.
- C. Security: Coordinate installation of door hardware, keying, and access control with Owner's security consultant.
- D. Electrical System Roughing-In: Coordinate layout and installation of electrified door hardware with connections to power supplies and building safety and security systems.

### 1.07 WARRANTY

- A. Manufacturer's standard form in which manufacturer agrees to repair or replace components of door hardware that fail in materials or workmanship within published warranty period.
  - 1. Warranty does not cover damage or faulty operation due to improper installation, improper use or abuse.
  - 2. Warranty Period: Beginning from date of Substantial Completion, for durations indicated in manufacturer's published listings.
    - a. Mechanical Warranty
      - 1) Locks
        - a) Schlage ND Series: 10 years
      - 2) Exit Devices
        - a) Von Duprin: 10 years
      - 3) Closers
        - a) LCN 4000 Series: 30 years
      - 4) Automatic Operators
        - a) LCN: 2 years
    - b. Electrical Warranty
      - 1) Locks
        - a) Schlage: 3 years
      - 2) Exit Devices
        - a) Von Duprin: 3 years

### 1.08 MAINTENANCE

- A. Furnish complete set of special tools required for maintenance and adjustment of hardware, including changing of cylinders.
- B. Turn over unused materials to Owner for maintenance purposes.

## PART 2 - PRODUCTS

### 2.01 MANUFACTURERS

## Logan City SD Mount Logan Middle School Vestibule Remodel

- A. The Owner requires use of certain products for their unique characteristics and project suitability to ensure continuity of existing and future performance and maintenance standards. After investigating available product offerings, the Awarding Authority has elected to prepare proprietary specifications. These products are specified with the notation: "No Substitute."
  - 1. Where "No Substitute" is noted, submittals and substitution requests for other products will not be considered.
- B. Approval of alternate manufacturers and/or products other than those listed as "Scheduled Manufacturer" or "Acceptable Manufacturers" in the individual article for the product category are only to be considered by official substitution request in accordance with section 01 25 00.
- C. Approval of products from manufacturers indicated in "Acceptable Manufacturers" is contingent upon those products providing all functions and features and meeting all requirements of scheduled manufacturer's product.
- D. Where specified hardware is not adaptable to finished shape or size of members requiring hardware, furnish suitable types having same operation and quality as type specified, subject to Architect's approval.

### 2.02 MATERIALS

- A. Fabrication
  - 1. Provide door hardware manufactured to comply with published templates generally prepared for machine, wood, and sheet metal screws. provide screws according to manufacturer's recognized installation standards for application intended.
  - 2. Finish exposed screws to match hardware finish, or, if exposed in surfaces of other work, to match finish of this other work including prepared for paint surfaces to receive painted finish.
  - 3. Provide concealed fasteners wherever possible for hardware units exposed when door is closed. Coordinate with "Metal Doors and Frames", "Flush Wood Doors", "Stile and Rail Wood Doors" to ensure proper reinforcements. Advise the Architect where visible fasteners, such as thru bolts, are required.
- B. Provide screws, bolts, expansion shields, drop plates and other devices necessary for hardware installation.
  - 1. Where fasteners are exposed to view: Finish to match adjacent door hardware material.
- C. Cable and Connectors:
  - 1. Where scheduled in the hardware sets, provide each item of electrified hardware and wire harnesses with number and gage of wires enough to accommodate electric function of specified hardware.
  - 2. Provide Molex connectors that plug directly into connectors from harnesses, electric locking and power transfer devices.
  - 3. Provide through-door wire harness for each electrified locking device installed in a door and wire harness for each electrified hinge, electrified continuous hinge, electrified pivot, and electric power transfer for connection to power supplies.

### 2.03 HINGES

## Logan City SD Mount Logan Middle School Vestibule Remodel

### A. Manufacturers and Products:

1. Scheduled Manufacturer and Product:
  - a. Ives 5BB series
2. Acceptable Manufacturers and Products:
  - a. Hager BB1191/1279 series
  - b. McKinney TB series
  - c. Best FBB series

### B. Requirements:

1. Provide hinges conforming to ANSI/BHMA A156.1.
2. Provide five knuckle, ball bearing hinges.
3. 1-3/4 inch (44 mm) thick doors, up to and including 36 inches (914 mm) wide:
  - a. Exterior: Standard weight, bronze or stainless steel, 4-1/2 inches (114 mm) high
  - b. Interior: Standard weight, steel, 4-1/2 inches (114 mm) high
4. 1-3/4 inch (44 mm) thick doors over 36 inches (914 mm) wide:
  - a. Exterior: Heavy weight, bronze/stainless steel, 5 inches (127 mm) high
  - b. Interior: Heavy weight, steel, 5 inches (127 mm) high
5. 2 inches or thicker doors:
  - a. Exterior: Heavy weight, bronze or stainless steel, 5 inches (127 mm) high
  - b. Interior: Heavy weight, steel, 5 inches (127 mm) high
6. Adjust hinge width for door, frame, and wall conditions to allow proper degree of opening.
7. Provide three hinges per door leaf for doors 90 inches (2286 mm) or less in height, and one additional hinge for each 30 inches (762 mm) of additional door height.
8. Hinge Pins: Except as otherwise indicated, provide hinge pins as follows:
  - a. Steel Hinges: Steel pins
  - b. Non-Ferrous Hinges: Stainless steel pins
  - c. Out-Swinging Exterior Doors: Non-removable pins
  - d. Out-Swinging Interior Lockable Doors: Non-removable pins
  - e. Interior Non-lockable Doors: Non-rising pins
9. Provide hinges with electrified options as scheduled in the hardware sets. Provide with number and gage of wires enough to accommodate electric function of specified hardware. Locate electric hinge at second hinge from bottom or nearest to electrified locking component. Provide mortar guard for each electrified hinge specified.

## 2.04 CONTINUOUS HINGES

### A. Manufacturers:

1. Scheduled Manufacturer:
  - a. Ives
2. Acceptable Manufacturers:
  - a. Select
  - b. Best
  - c. Roton
  - d. ABH
  - e. Hager

### B. Requirements:

Project: Logan City SD Mount Logan Middle School  
Vestibule Remodel  
Print Date: 04/01/2026

Allegion: OPT0476993

## Logan City SD Mount Logan Middle School Vestibule Remodel

1. Provide aluminum geared continuous hinges conforming to ANSI/BHMA A156.26, Grade 1.
2. Provide aluminum geared continuous hinges, where specified in the hardware sets, fabricated from 6063-T6 aluminum.
3. Provide split nylon bearings at each hinge knuckle for quiet, smooth, self-lubricating operation.
4. Provide hinges capable of supporting door weights up to 450 pounds, and successfully tested for 1,500,000 cycles.
5. On fire-rated doors, provide aluminum geared continuous hinges classified for use on rated doors by testing agency acceptable to authority having jurisdiction.
6. Provide aluminum geared continuous hinges with electrified option scheduled in the hardware sets. Provide with number and gage of wires enough to accommodate electric function of specified hardware.
7. Provide hinges 1 inch (25 mm) shorter in length than nominal height of door, unless otherwise noted or door details require shorter length and with symmetrical hole pattern.

### 2.05 ELECTRIC POWER TRANSFER

#### A. Manufacturers:

1. Scheduled Manufacturer and Product:
  - a. Von Duprin EPT-10
2. Acceptable Manufacturers and Products:
  - a. No Substitute -Owner's Standard

#### B. Requirements:

1. Provide power transfer with electrified options as scheduled in the hardware sets. Provide with number and gage of wires enough to accommodate electric function of specified hardware.
2. Locate electric power transfer per manufacturer's template and UL requirements, unless interference with operation of door or other hardware items.

### 2.06 CYLINDRICAL LOCKS – GRADE 1

#### A. Manufacturers and Products:

1. Scheduled Manufacturer and Product:
  - a. Schlage ND series
2. Acceptable Manufacturers and Products:
  - a. No Substitute -Owner's Standard

#### B. Requirements:

1. Provide cylindrical locks conforming to ANSI/BHMA A156.2 Series 4000, Grade 1, and UL Listed for 3-hour fire doors.
2. Indicators: Where specified, provide escutcheon with lock status indicator window on top of lockset rose:
  - a. Escutcheon height (including rose) 6.05 inches high by 3.68 inches wide.
  - b. Indicator window measuring a minimum 3.52-inch by .60 inch with 1.92 square-inches of front facing viewing area and 180-degree visibility with a total of .236 square-inches of total viewable area.

## Logan City SD Mount Logan Middle School Vestibule Remodel

- c. Provide snap-in serviceable window to prevent tampering. Lock must function if indicator is compromised.
  - d. Provide messages color-coded with full text and symbol, as scheduled, for easy visibility.
  - e. Unlocked and Unoccupied message will display on white background, and Locked and Occupied message will display on red background.
3. Cylinders: Refer to "KEYING" article, herein.
  4. Provide locks with standard 2-3/4 inches (70 mm) backset, unless noted otherwise, with 1/2-inch latch throw. Provide proper latch throw for UL listing at pairs.
  5. Provide locksets with separate anti-rotation thru-bolts, and no exposed screws.
  6. Provide independently operating levers with two external return spring cassettes mounted under roses to prevent lever sag.
  7. Provide standard ASA strikes unless extended lip strikes are necessary to protect trim.
  8. Provide electrified options as scheduled in the hardware sets.
  9. Lever Trim: Solid cast levers without plastic inserts and wrought roses on both sides.
    - a. Lever Design: RHO

### 2.07 EXIT DEVICES

#### A. Manufacturers and Products:

1. Scheduled Manufacturer and Product:
  - a. Von Duprin 98/35A series
2. Acceptable Manufacturers and Products:
  - a. No Substitute -Owner's Standard

#### B. Requirements:

1. Provide exit devices tested to ANSI/BHMA A156.3 Grade 1 and UL listed for Panic Exit or Fire Exit Hardware.
2. Cylinders: Refer to "KEYING" article, herein.
3. Provide smooth touchpad type exit devices, fabricated of brass, bronze, stainless steel, or aluminum, plated to standard architectural finishes to match balance of door hardware.
4. Touchpad must extend a minimum of one half of door width. No plastic inserts are allowed in touchpads.
5. Provide exit devices with deadlatching feature for security and for future addition of alarm kits and/or other electrified requirements.
6. Provide exit devices at pool gates with weather resistant components that can withstand harsh conditions of various climates and corrosive cleaners used in outdoor pool environments.
7. Provide flush end caps for exit devices.
8. Provide exit devices with manufacturers' approved strikes.
9. Provide exit devices cut to door width and height. Install exit devices at height recommended by exit device manufacturer, allowable by governing building codes, and approved by Architect.
10. Mount mechanism case flush on face of doors or provide spacers to fill gaps behind devices. Where glass trim or molding projects off face of door, provide glass bead kits.
11. Provide cylinder or hex-key dogging as specified at non fire-rated openings.
12. Removable Mullions: 2 inches (51 mm) x 3 inches (76 mm) steel tube. Where scheduled as keyed removable mullion, provide type that can be removed by use of a keyed cylinder, which is self-locking when re-installed.
13. Provide factory drilled weep holes for exit devices used in full exterior application, highly corrosive areas, and where noted in hardware sets.

## Logan City SD Mount Logan Middle School Vestibule Remodel

14. Provide electrified options as scheduled.
15. Top latch mounting: double- or single-tab mount for steel doors, face mount for aluminum doors eliminating requirement of tabs, and double tab mount for wood doors.
16. Provide exit devices with optional trim designs to match other lever and pull designs used on the project.

### 2.08 CYLINDERS

#### A. Manufacturers:

1. Scheduled Manufacturer and Product:
  - a. SFIC Medeco X4
2. Acceptable Manufacturers and Products:
  - a. No Substitute -Owner's Standard

#### B. Requirements:

1. Provide cylinders/cores to match Owner's existing key system, compliant with ANSI/BHMA A156.5; latest revision; cylinder face finished to match lockset, manufacturer's series as indicated. Refer to "KEYING" article, herein.

### 2.09 KEYING

#### A. Scheduled System:

1. New factory registered system:
  - a. Provide a factory registered keying system, complying with guidelines in ANSI/BHMA A156.28, incorporating decisions made at keying conference.
2. Existing factory registered system:
  - a. Provide cylinders/cores keyed into Owner's existing factory registered keying system. Comply with guidelines in ANSI/BHMA A156.28, incorporating decisions made at keying conference.

#### B. Requirements:

1. Construction Keying:
  - a. Replaceable Construction Cores.
    - 1) Provide temporary construction cores replaceable by permanent cores, furnished in accordance with the following requirements.
      - a) 3 construction control keys
      - b) 12 construction change (day) keys.
    - 2) Owner or Owner's Representative will replace temporary construction cores with permanent cores.
2. Permanent Keying:
  - a. Provide permanent cylinders/cores keyed by the manufacturer according to the following key system.
    - 1) Master Keying system as directed by the Owner.
  - b. Forward biting list and keys separately from cylinders, by means as directed by Owner. Failure to comply with forwarding requirements will be cause for replacement of cylinders/cores involved at no additional cost to Owner.
  - c. Provide keys with the following features:

## Logan City SD Mount Logan Middle School Vestibule Remodel

- 1) Material: Nickel silver; minimum thickness of .107-inch (2.3mm)
- 2) Patent Protection: Keys and blanks protected by one or more utility patent(s).
- d. Identification:
  - 1) Mark permanent cylinders/cores and keys with applicable blind code for identification. Do not provide blind code marks with actual key cuts.
  - 2) Identification stamping provisions must be approved by the Architect and Owner.
  - 3) Stamp cylinders/cores and keys with Owner's unique key system facility code as established by the manufacturer; key symbol and embossed or stamped with "DO NOT DUPLICATE" along with the "PATENTED" or patent number to enforce the patent protection.
  - 4) Failure to comply with stamping requirements will be cause for replacement of keys involved at no additional cost to Owner.
  - 5) Forward permanent cylinders/cores to Owner, separately from keys, by means as directed by Owner.
- e. Quantity: Furnish in the following quantities.
  - 1) Permanent Control Keys: 3.
  - 2) Master Keys: 6.
  - 3) Change (Day) Keys: 3 per cylinder/core that is keyed differently
  - 4) Key Blanks: Quantity as determined in the keying meeting.

### 2.10 DOOR CLOSERS

#### A. Manufacturers and Products:

1. Scheduled Manufacturer and Product:
  - a. LCN 4040XP series
2. Acceptable Manufacturers and Products:
  - a. No Substitute -Owner's Standard

#### B. Requirements:

1. Provide door closers conforming to ANSI/BHMA A156.4 Grade 1 requirements by BHMA certified independent testing laboratory. ISO 9000 certify closers. Stamp units with date of manufacture code.
2. Provide door closers with fully hydraulic, full rack and pinion action with high strength cast iron cylinder, and full complement bearings at shaft.
3. Cylinder Body: 1-1/2-inch (38 mm) diameter piston with 5/8-inch (16 mm) diameter double heat-treated pinion journal. QR code with a direct link to maintenance instructions.
4. Hydraulic Fluid: Fireproof, passing requirements of UL10C, and requiring no seasonal closer adjustment for temperatures ranging from 120 degrees F to -30 degrees F.
5. Spring Power: Continuously adjustable over full range of closer sizes, and providing reduced opening force as required by accessibility codes and standards. Provide snap-on cover clip, with plastic covers, that secures cover to spring tube.
6. Hydraulic Regulation: By tamper-proof, non-critical valves, with separate adjustment for latch speed, general speed, and backcheck. Provide graphically labelled instructions on the closer body adjacent to each adjustment valve. Provide positive stop on reg valve that prevents reg screw from being backed out.
7. Provide closers with solid forged steel main arms and factory assembled heavy-duty forged forearms for parallel arm closers.
8. Pressure Relief Valve (PRV) Technology: Not permitted.
9. Finish for Closer Cylinders, Arms, Adapter Plates, and Metal Covers: Powder coating finish which has been certified to exceed 100 hours salt spray testing as described in ANSI Standard A156.4 and ASTM B117, or has special rust inhibitor (SRI).

## Logan City SD Mount Logan Middle School Vestibule Remodel

10. Provide special templates, drop plates, mounting brackets, or adapters for arms as required for details, overhead stops, and other door hardware items interfering with closer mounting.
11. Closers shall be capable of being upgraded by adding modular mechanical or electronic components in the field.

### 2.11 ELECTROMECHANICAL AUTOMATIC OPERATORS

#### A. Manufacturers and Products:

1. Scheduled Manufacturer and Product:
  - a. LCN Senior Swing
2. Acceptable Manufacturers and Products:
  - a. No Substitute -Owner's Standard

#### B. Requirements:

1. Provide low energy automatic operator units that are electromechanical design complying with ANSI/BHMA A156.19.
  - a. Opening: Powered by DC motor working through reduction gears.
  - b. Closing: Spring force.
  - c. Manual, hydraulic, or chain drive closers: Not permitted.
  - d. Operation: Motor is off when door is in closing mode. Door can be manually operated with power on or off without damage to operator. Provide variable adjustments, including opening and closing speed adjustment.
  - e. Cover: Aluminum.
2. Provide units with manual off/auto/hold-open switch, push and go function to activate power operator, vestibule interface delay, electric lock delay, hold-open delay adjustable from 1 to 32 seconds, and logic terminal to interface with accessories, mats, and sensors.
3. Provide drop plates, brackets, and adapters for arms as required to suit details.
4. Provide motion sensors and/or actuator switches, and receivers for operation as specified. Provide weather-resistant actuators at exterior applications.
5. Provide key switches, with LED's, recommended and approved by manufacturer of automatic operator as required for function as described in operation description of hardware sets. Cylinders: Refer to "KEYING" article, herein.
6. Provide complete assemblies of controls, switches, power supplies, relays, and parts/material recommended and approved by manufacturer of automatic operator for each individual leaf. Actuators control both doors simultaneously at pairs. Sequence operation of exterior and vestibule doors with automatic operators to allow ingress or egress through both sets of openings as directed by Architect. Locate actuators, key switches, and other controls as directed by Architect.

### 2.12 PROTECTION PLATES

#### A. Manufacturers:

1. Scheduled Manufacturer:
  - a. Ives
2. Acceptable Manufacturers:
  - a. Trimco
  - b. Rockwood

B. Requirements:

1. Provide protection plates with a minimum of 0.050 inch (1 mm) thick, beveled four edges as scheduled. Furnish with sheet metal or wood screws, finished to match plates.
2. Sizes plates 2 inches (51 mm) less width of door on single doors, pairs of doors with a mullion, and doors with edge guards. Size plates 1 inch (25 mm) less width of door on pairs without a mullion or edge guards.
3. At fire rated doors, provide protection plates over 16 inches high with UL label.

2.13 OVERHEAD STOPS AND OVERHEAD STOP/HOLDERS

A. Manufacturers:

1. Scheduled Manufacturers:
  - a. Glynn-Johnson
2. Acceptable Manufacturers:
  - a. Rixson
  - b. Sargent

B. Requirements:

1. Provide overhead stop at any door where conditions do not allow for a wall stop or floor stop presents tripping hazard.

2.14 DOOR STOPS AND HOLDERS

A. Manufacturers:

1. Scheduled Manufacturer:
  - a. Ives
2. Acceptable Manufacturers:
  - a. Trimco
  - b. Rockwood

B. Provide door stops at each door leaf:

1. Provide wall stops wherever possible. Provide concave type where lockset has a push button of thumbturn.
2. Where a wall stop cannot be used, provide universal floor stops.
3. Where wall or floor stop cannot be used, provide overhead stop.
4. Provide roller bumper where doors open into each other and overhead stop cannot be used.

2.15 SILENCERS

A. Manufacturers:

1. Scheduled Manufacturer:
  - a. Ives
2. Acceptable Manufacturers:

## Logan City SD Mount Logan Middle School Vestibule Remodel

- a. Rockwood
- b. Trimco

### B. Requirements:

1. Provide "push-in" type silencers for hollow metal or wood frames.
2. Provide one silencer per 30 inches (762 mm) of height on each single frame, and two for each pair frame.
  - a. Zero International
  - b. No Substitute
  - c. National Guard
  - d. Reese
  - e. Pemko
3. Omit where gasketing is specified.

## 2.16 THRESHOLDS, SEALS, DOOR SWEEPS, AUTOMATIC DOOR BOTTOMS, AND GASKETING

### A. Manufacturers:

### B. Scheduled Manufacturer:

1. Zero International

### C. Acceptable Manufacturers:

1. National Guard
2. Pemko

## 2.17 DOOR POSITION SWITCHES

### A. Manufacturers:

1. Scheduled Manufacturer:
  - a. Schlage
2. Acceptable Manufacturers:
  - a. GE-Interlogix
  - b. Sargent

### B. Requirements:

1. Provide recessed or surface mounted type door position switches as specified.
2. Coordinate door and frame preparations with door and frame suppliers. If switches are being used with magnetic locking device, provide minimum of 4 inches (102 mm) between switch and magnetic locking device.

## 2.18 FINISHES

### A. FINISH: BHMA 626/652 (US26D); EXCEPT:

1. Hinges at Exterior Doors: BHMA 630 (US32D)

## Logan City SD Mount Logan Middle School Vestibule Remodel

2. Aluminum Geared Continuous Hinges: BHMA 628 (US28)
3. Push Plates, Pulls, and Push Bars: BHMA 630 (US32D)
4. Protection Plates: BHMA 630 (US32D)
5. Overhead Stops and Holders: BHMA 630 (US32D)
6. Door Closers: Powder Coat to Match
7. Wall Stops: BHMA 630 (US32D)
8. Latch Protectors: BHMA 630 (US32D)
9. Weatherstripping: Clear Anodized Aluminum
10. Thresholds: Mill Finish Aluminum

### PART 3 - EXECUTION

#### 3.01 EXAMINATION

- A. Prior to installation of hardware, examine doors and frames, with Installer present, for compliance with requirements for installation tolerances, labeled fire-rated door assembly construction, wall and floor construction, and other conditions affecting performance. Verify doors, frames, and walls have been properly reinforced for hardware installation.
- B. Examine roughing-in for electrical power systems to verify actual locations of wiring connections before electrified door hardware installation.
- C. Submit a list of deficiencies in writing and proceed with installation only after unsatisfactory conditions have been corrected.

#### 3.02 INSTALLATION

- A. Mount door hardware units at heights to comply with the following, unless otherwise indicated or required to comply with governing regulations.
  1. Standard Steel Doors and Frames: ANSI/SDI A250.8.
  2. Custom Steel Doors and Frames: HMMA 831.
  3. Interior Architectural Wood Flush Doors: ANSI/WDMA I.S. 1A
  4. Installation Guide for Doors and Hardware: DHI TDH-007-20
- B. Install door hardware in accordance with NFPA 80, NFPA 101 and provide post-install inspection, testing as specified in section 1.03.E unless otherwise required to comply with governing regulations.
- C. Install each hardware item in compliance with manufacturer's instructions and recommendations, using only fasteners provided by manufacturer.
- D. Do not install surface mounted items until finishes have been completed on substrate. Protect all installed hardware during painting.
- E. Set units level, plumb and true to line and location. Adjust and reinforce attachment substrate as necessary for proper installation and operation.
- F. Drill and countersink units that are not factory prepared for anchorage fasteners. Space fasteners and anchors according to industry standards.

Logan City SD Mount Logan Middle School Vestibule Remodel

- G. Install operating parts so they move freely and smoothly without binding, sticking, or excessive clearance.
- H. Hinges: Install types and in quantities indicated in door hardware schedule but not fewer than quantity recommended by manufacturer for application indicated.
- I. Lock Cylinders:
  - 1. Install construction cores to secure building and areas during construction period.
  - 2. Replace construction cores with permanent cores as indicated in keying section.
  - 3. Furnish permanent cores to Owner for installation.
- J. Wiring: Coordinate with Division 26, ELECTRICAL and Division 28 ELECTRONIC SAFETY AND SECURITY sections for:
  - 1. Conduit, junction boxes and wire pulls.
  - 2. Connections to and from power supplies to electrified hardware.
  - 3. Connections to fire/smoke alarm system and smoke evacuation system.
  - 4. Connection of wire to door position switches and wire runs to central room or area, as directed by Architect.
  - 5. Connections to panel interface modules, controllers, and gateways.
  - 6. Testing and labeling wires with Architect's opening number.
- K. Key Control System: Tag keys and place them on markers and hooks in key control system cabinet, as determined by final keying schedule.
- L. Continuous Hinges: Re-locate the door and frame fire rating labels where they will remain visible so that the hinge does not cover the label once installed.
- M. Door Closers & Auto Operators: Mount closers/operators on room side of corridor doors, inside of exterior doors, and stair side of stairway doors from corridors. Mount closers/operators so they are not visible in corridors, lobbies and other public spaces unless approved by Architect.
- N. Overhead Stops/holders: Mount overhead stops/holders on room side of corridor doors, inside of exterior doors, and stair side of stairway doors.
- O. Power Supplies: Locate power supplies as indicated or, if not indicated, above accessible ceilings or in equipment room, or alternate location as directed by Architect.
- P. Thresholds:
  - 1. Set thresholds in full bed of sealant complying with requirements specified in Division 07 Section "Joint Sealants."
  - 2. Aluminum thresholds to be cut-in, and scribed around mullions, frame members, and stops. Do not butt to thresholds. Provide a continuous surface across full width of opening from jamb to jamb.
  - 3. Where aluminum panic-type (rabbeted) thresholds with neoprene inserts are specified, undercut doors as required to properly mate with seal in threshold.
- Q. Stops: Provide floor stops for doors unless wall or other type stops are indicated in door hardware schedule. Do not mount floor stops where they may impede traffic or present tripping hazard.
- R. Perimeter Gasketing:

## Logan City SD Mount Logan Middle School Vestibule Remodel

1. Apply to head and jamb, forming seal between door and frame.
  2. Install gasketing in a manner eliminating need to cut any seal to install surface mounted hardware. Install compatible mounting bracket for surface mounted hardware unless minimum 1/4 inch thick solid aluminum seals are provided for mounting of surface applied hardware.
- S. Meeting Stile Gasketing: Fasten to meeting stiles, forming seal when doors are closed.
- T. Door Bottoms and Sweeps: Apply to bottom of door, forming seal with threshold when door is closed.

### 3.03 ADJUSTING

- A. Initial Adjustment: Adjust and check each operating item of door hardware and each door to ensure proper operation or function of every unit. Replace units that cannot be adjusted to operate as intended. Adjust door control devices to compensate for final operation of heating and ventilating equipment and to comply with referenced accessibility requirements.
1. Spring Hinges: Adjust to achieve positive latching when door can close freely from an open position of 30 degrees.
  2. Electric Strikes: Adjust horizontal and vertical alignment of keeper to properly engage lock bolt.
  3. Door Closers: Adjust sweep period to comply with accessibility requirements and requirements of authorities having jurisdiction.
- B. Occupancy Adjustment: Approximately three to six months after date of Substantial Completion, examine and readjust each item of door hardware, including adjusting operating forces, as necessary to ensure function of doors and door hardware.

### 3.04 CLEANING AND PROTECTION

- A. Clean adjacent surfaces soiled by door hardware installation.
- B. Clean operating items per manufacturer's instructions to restore proper function and finish.
- C. Provide final protection and maintain conditions that ensure door hardware is without damage or deterioration at time of Substantial Completion.

### 3.05 DOOR HARDWARE SCHEDULE

- A. The intent of the hardware specification is to specify the hardware for interior and exterior doors, and to establish a type, continuity, and standard of quality. However, it is the door hardware supplier's responsibility to thoroughly review existing conditions, schedules, specifications, drawings, and other Contract Documents to verify the suitability of the hardware specified.
- B. Discrepancies, conflicting hardware, and missing items are to be brought to the attention of the architect with corrections made prior to the bidding process. Omitted items not included in a hardware set should be scheduled with the appropriate additional hardware required for proper application.

Logan City SD Mount Logan Middle School Vestibule Remodel

C. Hardware items are referenced in the following hardware schedule. Refer to the above specifications for special features, options, cylinders/keying, and other requirements.

D. Hardware Sets:

Abbreviation	Name
GLY	Glynn-Johnson Corp
IVE	H.B. Ives
LCN	LCN Commercial Division
MED	Medeco High Security Locks Inc
SCE	Schlage Electronic Security
SCH	Schlage Lock Company
VON	Von Duprin
ZER	Zero International Inc

149528 OPT0476993 Version 1

**HW SET: 01**

For use on Door #(s):

109                      110A

Each to have:

3	EA	HINGE	5BB1HW 4.5 X 4.5 NRP		652	IVE
1	EA	POWER TRANSFER	EPT10 CON		↗ 689	VON
1	EA	EU STOREROOM LOCK	ND80BDEU RHO RX CON 12V/24V DC		↗ 626	SCH
1	EA	SFIC CORE	X4		626	MED
1	EA	SURFACE CLOSER	4040XP CUSH		689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS TKTX		630	IVE
3	EA	SILENCER	SR64		GRY	IVE
1	EA	WIRE HARNESS (DOOR)	CON-XX (REQ. LENGTH)		↗	SCH
1	EA	FRAME HARNESS	CON-6W		↗	SCH
1	EA	CREDENTIAL READER	BY DIVISION 28.		↗	
1	EA	DOOR CONTACT	679-05HM		BLK	SCE
1	EA	LOW VOLTAGE POWER	BY DIVISION 28.		↗	

**OPERATION:**

DOOR NORMALLY CLOSED AND SECURE.

USER PRESENTS CREDENTIAL MOMENTARILY UNLOCKING OUTSIDE LEVER, USER ROTATES LEVER FOR ENTRY

EGRESS AT ALL TIMES BY INTERIOR LEVER

DOOR POSITION MONITORED BY ACCESS CONTROL

REQUEST TO EXIT IS PART OF THE LOCKSET








Logan City SD Mount Logan Middle School Vestibule Remodel

**HW SET: 02**

For use on Door #(s):

124A                      124B

Each to have:

2	EA	HINGE	5BB1HW 4.5 X 4.5 NRP (HINGES TO MATCH EXISTING FRAME AND DOOR SIZE)		652	IVE
1	EA	ELECTRIC HINGE	5BB1HW 4.5 X 4.5 CON TW8 (HINGE TO MATCH EXISTING FRAME AND DOOR SIZE)	 ↗	652	IVE
1	EA	EU STOREROOM LOCK	ND80BDEU RHO RX CON 12V/24V DC	 ↗	626	SCH
1	EA	SFIC CORE	X4		626	MED
1	EA	SURFACE CLOSER	4040XP RW/PA		689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS TKTX		630	IVE
3	EA	SILENCER	SR64		GRY	IVE
1	EA	WIRE HARNESS (DOOR)	CON-XX (REQ. LENGTH)		↗	SCH
1	EA	FRAME HARNESS	CON-6W		↗	SCH
1	EA	CREDENTIAL READER	BY DIVISION 28.		↗	
1	EA	DOOR CONTACT	679-05HM		BLK	SCE
1	EA	LOW VOLTAGE POWER	BY DIVISION 28.		↗	

OPERATION:







DOOR NORMALLY CLOSED AND SECURE.  
 USER PRESENTS CREDENTIAL MOMENTARILY UNLOCKING OUTSIDE LEVER, USER ROTATES LEVER FOR ENTRY  
 EGRESS AT ALL TIMES BY INTERIOR LEVER  
 DOOR POSITION MONITORED BY ACCESS CONTROL  
 REQUEST TO EXIT IS PART OF THE LOCKSET

**HW SET: 03**

For use on Door #(s):

139

Each to have:

3	EA	HINGE	5BB1 4.5 X 4.5 NRP		652	IVE
1	EA	STOREROOM LOCK	ND80BD RHO		626	SCH
1	EA	SFIC CORE	X4		626	MED
1	EA	SURFACE CLOSER	4040XP RW/PA		689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS TKTX		630	IVE
1	EA	WALL STOP	WS406/407CVX		630	IVE
3	EA	SILENCER	SR64		GRY	IVE







Logan City SD Mount Logan Middle School Vestibule Remodel

**HW SET: 04**

For use on Door #(s):

128

Each to have:





3	EA	HINGE	5BB1 4.5 X 4.5 NRP		652	IVE
1	EA	CLASSROOM LOCK	ND70BD RHO		626	SCH
1	EA	SFIC CORE	X4		626	MED
1	EA	SURFACE CLOSER	4040XP EDA		689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS TKTX		630	IVE
1	EA	WALL STOP	WS406/407CVX		630	IVE
3	EA	SILENCER	SR64		GRY	IVE

**HW SET: 05**

For use on Door #(s):

112                      119

Each to have:







3	EA	HINGE	5BB1 4.5 X 4.5 NRP		652	IVE
1	EA	ENTRANCE LOCK	ND53BD RHO		626	SCH
1	EA	SFIC CORE	X4		626	MED
1	EA	WALL STOP	WS406/407CCV		630	IVE
3	EA	SILENCER	SR64		GRY	IVE

**HW SET: 06**

For use on Door #(s):

114A                      114B

Each to have:







3	EA	HINGE	5BB1 4.5 X 4.5 NRP		652	IVE
1	EA	ENTRANCE LOCK	ND53BD RHO		626	SCH
1	EA	SFIC CORE	X4		626	MED
1	EA	SURFACE CLOSER	4040XP RW/PA		689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS TKTX		630	IVE
1	EA	WALL STOP	WS406/407CCV		630	IVE
3	EA	SILENCER	SR64		GRY	IVE

Logan City SD Mount Logan Middle School Vestibule Remodel

**HW SET: 07**

For use on Door #(s):  
127








Each to have:

3	EA	HINGE	5BB1 4.5 X 4.5 NRP		652	IVE
1	EA	PRIVACY LOCK W/ OUTSIDE INDICATOR	ND40S RHO OS-OCC		626	SCH
1	EA	SURFACE CLOSER	4040XP RW/PA		689	LCN
1	EA	KICK PLATE	8400 10" X 2" LDW B-CS TKTX		630	IVE
1	EA	WALL STOP	WS406/407CCV		630	IVE
1	EA	GASKETING	488SBK PSA		BK	ZER

**HW SET: A1**

For use on Door #(s):  
100C

Each to have:

1	EA	CONT. HINGE	112XY EPT		628	IVE
1	EA	POWER TRANSFER	EPT10 CON		↗ 689	VON
1	EA	EU STOREROOM LOCK	ND80BDEU RHO RX CON 12V/24V DC		↗ 626	SCH
1	EA	SFIC CORE	X4		626	MED
1	EA	OH STOP	100S ADJ		630	GLY
1	EA	SURFACE CLOSER	4040XP EDAW/62G TBWMS		689	LCN
1	EA	PA MOUNTING PLATE	4040XP-18PA		689	LCN
1	EA	PERIMETER GASKET	BY DOOR ASSEMBLY MANUFACTURER			
1	EA	DOORBELL./ INTERCOM	BY DIVISION 28		↗	
1	EA	WIRE HARNESS (DOOR)	CON-XX (REQ. LENGTH)		↗	SCH
1	EA	FRAME HARNESS	CON-6W		↗	SCH
1	EA	CREDENTIAL READER	BY DIVISION 28.		↗	
1	EA	DOOR CONTACT	679-05HM		BLK	SCE
1	EA	LOW VOLTAGE POWER	BY DIVISION 28.		↗	

**OPERATION:**

DOOR NORMALLY CLOSED AND SECURE.  
 USER PRESENTS CREDENTIAL MOMENTARILY UNLOCKING OUTSIDE LEVER, USER ROTATES LEVER FOR ENTRY  
 EGRESS AT ALL TIMES BY INTERIOR LEVER  
 DOOR POSITION MONITORED BY ACCESS CONTROL  
 REQUEST TO EXIT IS PART OF THE LOCKSET  
 ENTRY MAY BE GRANTED BY REMOTE RELEASE / INTERCOM











Logan City SD Mount Logan Middle School Vestibule Remodel

**HW SET: A2**

For use on Door #(s):

100A

Each to have:

2	EA	CONT. HINGE	112XY EPT		628	IVE
2	EA	POWER TRANSFER	EPT10 CON	 ↗	689	VON
1	EA	REMOVABLE MULLION	KR4954B STAB		689	VON
1	EA	ELEC PANIC HARDWARE	RX-QEL-98-DT 24 VDC	 ↗	626	VON
1	EA	ELEC PANIC HARDWARE	RX-QEL-98-NL 24 VDC	 ↗	626	VON
1	EA	SFIC MORTISE CYL.	80-105 (CAM AS REQ'D)		626	SCH
1	EA	SFIC RIM HOUSING	80-129		626	SCH
2	EA	SFIC CORE	X4		626	MED
2	EA	OH STOP	100S ADJ		630	GLY
1	EA	SURFACE CLOSER	4040XP EDAW/62G TBWMS		689	LCN
1	EA	SURF. AUTO OPERATOR	9542IQ TLS NO TRACK COV	 ↗	628	LCN
1	EA	PA MOUNTING PLATE	4040XP-18PA		689	LCN
2	EA	ACTUATOR, TOUCH	8310-853T	 ↗	630	LCN
1	EA	PERIMETER GASKET	BY DOOR ASSEMBLY MANUFACTURER			
2	EA	WIRE HARNESS (DOOR)	CON-XX (REQ. LENGTH)		↗	SCH
2	EA	FRAME HARNESS	CON-6W		↗	SCH
1	EA	CREDENTIAL READER	BY DIVISION 28.		↗	
1	EA	LOW VOLTAGE POWER	BY DIVISION 28.		↗	

**OPERATION:**

DOORS NORMALLY LOCKED.

USER PRESENTS CREDENTIAL, EXIT DEVICE LATCH RETRACTS, USER OPENS DOOR TO ENTER.

ENTRY BY AUTO OPERATOR BY USING ACTUATOR WHEN DOORS ARE UNLOCKED.

EXIT BY AUTO OPERATOR AT ALL TIMES BY USING INTERIOR ACTUATOR.

MANUAL EGRESS AT ALL TIMES BY EXIT DEVICE.

DOOR POSITION IS MONITORED BY ACCESS CONTROL SYSTEM

REQUEST TO EXIT IS PART OF EXIT DEVICE








DOORS MAY BE LOCKED /UNLOCKED BY SCHEDULE FROM ACCESS CONTROL SYSTEM

Logan City SD Mount Logan Middle School Vestibule Remodel

**HW SET: A3**

For use on Door #(s):  
100B

Each to have:

2	EA	CONT. HINGE	112XY EPT		628	IVE
2	EA	POWER TRANSFER	EPT10 CON		↗ 689	VON
1	EA	REMOVABLE MULLION	KR4954B STAB		689	VON
2	EA	ELEC PANIC HARDWARE	RX-QEL-98-DT 24 VDC		↗ 626	VON
1	EA	SFIC MORTISE CYL.	80-105 (CAM AS REQ'D)		626	SCH
1	EA	SFIC CORE	X4		626	MED
2	EA	OH STOP	100S ADJ		630	GLY
2	EA	SURFACE CLOSER	4040XP EDAW/62G TBWMS		689	LCN
2	EA	PA MOUNTING PLATE	4040XP-18PA		689	LCN
1	EA	PERIMETER GASKET	BY DOOR ASSEMBLY MANUFACTURER			
2	EA	WIRE HARNESS (DOOR)	CON-XX (REQ. LENGTH)		↗	SCH
2	EA	FRAME HARNESS	CON-6W		↗	SCH
1	EA	LOW VOLTAGE POWER	BY DIVISION 28.		↗	

OPERATION:  
DOORS NORMALLY LOCKED.  
DOORS MAY BE LOCKED /UNLOCKED BY SCHEDULE FROM ACCESS CONTROL SYSTEM  
MANUAL EGRESS AT ALL TIMES BY EXIT DEVICE.  
DOOR POSITION IS MONITORED BY ACCESS CONTROL SYSTEM  
REQUEST TO EXIT IS PART OF EXIT DEVICE

**HW SET: R1**

For use on Door #(s):  
124J

Each to have:

EA	NOTE	BALANCE OF HARDWARE BY ROLL-UP /OVERHEAD DOOR SUPPLIER /MANUFACTURER
----	------	--

END OF SECTION